TOWN OF GILBERT ADDENDUM NO.3 TO BID DOCUMENTS FOR

Project Name: Semi-Annual - Annual Generator Service Invitations For Bids (IFB) Number: 2014-1102-0280

May 14, 2014

This Addendum contains a total of 1 page http://www.gilbertaz.gov/rfp

The following revisions to the IFB Documents for the project shall become a part of the Contract Documents. Only these items are to be altered. There are no changes to the remainder of the original IFB Documents.

Supplemental Specifications and Clarifications

- 1. Page 17-18, Attachment 5 Bid Price:
 - a. Item #39 is a duplicate of Item #37. Item #39 is deleted from the bid sheet
 - b. **Add Additional 15Kw Generator to Item #11** North Water Treatment Plant, 2865 E Guadalupe Rd (total of 2 Generator's, one 2500Kw, one 15Kw)
 - c. Item #41 Water Treatment Plant South, a 2 hour plant load test is required

The Proposer shall acknowledge receipt of all addendums in their submittal. Failure to do so will result in the proposal being declared non-responsive.

Diane Shannon
Contract Specialist
Purchasing Division
Finance and Management Services
Diane.Shannon@gilbertaz.gov
480-503-6818